

## MSAD 75 Life Safety – Fire Protection Master List

Rev. 3, July 14, 2011; Rev. 4, 10/5/11; Rev.5, 8/29//12; Rev 6, 3/21/13; Rev 7, 3/27/17; Rev 8, 7/19/17; Rev.9,7/13/21

Facility	Water Source	Alternate Water Source	Sprinkler System	Spklr. Internal & Gage Last 5 Yr. Insp.	Fire Hydrants Annual	Hood Fire Sup. Semi Annual	Nearest Fire Station	Fire Extinguishers Monthly & Annual	Exit Lights Monthly	Emer. Lights Monthly	Det. & Alarm Annual	Elev. Recall Annual	Comments
<b>NEW Mt. Ararat HS</b>	Public	None	Yes – Wet & dry with Fire Pump	Spklr & gage new 6/20	4 - Districts	Kitchen, Health & spec Ed	Main St. 0.7 mi	Approx. 45	Approx. 60	Many lights on Emer Gen	YES	YES	Emer Gen supplies all critical loads & lighting -Natural Gas
<b>Mt. Ararat MS</b>	Public	Draft from Drain. Ponds	Yes – Wet with Jockey & Fire Pump	Spklr. 6/20/16 Gage 7/19/17	3 - Districts	Kitchen, Health & 2R	Main St. 0.9 mi	Approx. 39	Approx. 75	Approx. 133	YES	YES (2)	-Orion & Sch. lobby has smoke ejectors -Natural gas - Pump repacked: 4/18/12&flow test
<b>Woodside</b>	Public	None	Yes - Wet	Spklr 6/21/16 Gage 7/19/17	2 - Districts	Kitchen Spec. Ed	Main St. 0.9 mi	Approx. 25	Approx. 32	Approx. 35	YES	YES	Natural Gas
<b>Williams Cone</b>	Public	None	Yes - Wet	Spklr 6/20/16 Gage 7/19/17	1 - Public	Kitchen	Main St. 0.6 mi	Approx. 14	Approx. 28	Approx. 37	YES	N/A	-Em. Access behind Cone -Natural Gas
<b>Bowdoin</b>	Well - Storage Tk.	Draft Frm. Stoddards Pond	Yes – Wet with xfer & Jockey Pump	Spklr. 6/20/16 Gage 7/19/17	None	Kitchen & Spec. Ed	Cornish Dr. 1.5 mi	Approx. 13	Approx. 16	Approx. 52	YES	N/A Vertical Lift for Stage	-Underground Wtr. St. Tk., 6000 gal. tot., min. 5,000 Fire Prot., - 300gal Hypo Tk. -Natural Gas -Emer. Gen.
<b>Bowdoinham</b>	Public	None	Only in new wing Janitor closet	N/A	1 - Public	Kitchen	Old Post Rd. 0.5 mi	Approx. 18	Approx. 18	Approx. 24	YES	N/A	4,000 gal. Undgrd LP & FO Storage tanks -Emer. Gen.
<b>Harpwell Community (Formerly Islands)</b>	Well – Storage Tanks	None	Yes <b>only 2 old wings</b> – Wet with xfer pump	Spklr. 6/20/16 Gage 7/19/17	None	Kitchen	Cundy’s Hbr. Rd. 5.0 mi	Approx. 9	Approx. 17	Approx. 9	YES	N/A	3- 275 gal. Water St. Tks inside. -4,000 gal. Undgrd LP & FO Storage tanks -Emer. Gen.
<b>Bus Garage</b>	Public	None	None	N/A	1-Public @ Union Park Road Across St.	N/A	Main St. 0.5 mi	4 3-Bldg. 1- Fuel Island	2	1	YES	N/A	underground Fuel tanks - 4,000gal Diesel -1,000 gal gas
<b>Lodge/Ad Ed.</b>	Public	Draft from Drain. Ponds	Yes - Wet	Spklr 6/21/16 Gage 7/19/17	1 – Public 1 – Private (Housing)	Spec. Ed.	Main St. 0.9 mi	Approx. 9	Approx. 13	Approx. 17	YES	N/A	Natural gas
<b>Dist. Off.</b>	Public	Draft from Drain. Ponds	Yes - Wet	Spklr 6/20/16 Gage 7/19/17	1 – Dist. (shared with MS) 1 - Public	None	Main St. 0.9 mi	Approx. 10	Approx. 15	Approx. 7	YES	N/A	Natural gas
<b>Bldg. 376</b>	Public	Draft from Drain Pond	None	N/A	1 – Dist (shared with MS)	N/A	Main St. 0.9 mi	Approx. 6	Approx. 4	Approx. 6	None	N/A	External K-1 Fuel oil heating. Haz. Mat. Storage

